



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

RE: Seneca County
Fostoria Mobile Estates
Community System
PWS ID. #: 7400712

October 1, 2008

OH7400712

FOSTORIA MOBILE ESTATES

10/1/2008

Mr. Joe Raineri
P.O. Box 398
Bath, Ohio 44210



Dear Mr. Raineri:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Report (EPA 5002) (MOR) was not received for the public water system for the month of August 2008.

Free and combined chlorine residuals are required to be conducted at the plant tap and in the distribution system daily (seven days per week) according to OAC Rule 3745-83-01(G). Ohio Administrative Code (OAC), Rule 3745-83-01(I), requires submittal of an operational report no later than the tenth of the month following the month being reported [e.g., The Septemebr monthly operational report should be submitted to the district office no later than October 10th].

The owner / operator of Fostoria Mobile Estates is in violation of OAC Rule 3745-83-01(G), OAC Rule 3745-83-01(I) for not completing the above requirements.

If you have any questions regarding this letter, please contact me at (419) 373-3101.

Sincerely,

Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

/csl

pc: Toni Buchanan, IMS, DDAGW, CO
Lucas Stahl, Fostoria Mobile Estates
Seneca County Health Department
(DDAGW, NWDO File)