



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

RE: Seneca County  
Fostoria Mobile Estates  
Community System  
PWS ID. #: 7400712


OH7400712

FOSTORIA MOBILE ESTATES

9/3/2008

September 3, 2008

Mr. Joe Raineri  
P.O. Box 398  
Bath, Ohio 44210



Dear Mr. Raineri:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Report (EPA 5002) (MOR) was not received for the public water system for the month of July 2008.

Free and combined chlorine residuals are required to be conducted at the plant tap and in the distribution system daily (seven days per week) according to OAC Rule 3745-83-01(G). Ohio Administrative Code (OAC), Rule 3745-83-01(I), requires submittal of an operational report no later than the tenth of the month following the month being reported [e.g., The August monthly operational report should be submitted to the district office no later than September 10<sup>th</sup>].

**The owner / operator of Fostoria Mobile Estates is in violation of OAC Rule 3745-83-01(G), OAC Rule 3745-83-01(I) for not completing the above requirements.**

If you have any questions regarding this letter, please contact me at (419) 373-3101.

Sincerely,

Ben Smith  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/lb

pc: Toni Buchanan, IMS, DDAGW, CO  
Lucas Stahl, Fostoria Mobile Estates  
Seneca County Health Department

DDAGW\NWDO\File