



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

RE: Seneca County  
Fostoria Mobile Estates  
Community Water System  
PWS ID. #: 7400712

April 25, 2007

OH7400712

FOSTORIA MOBILE ESTATES

4/25/2007

Mr. Joe Raineri  
P.O. Box 398  
Bath, Ohio 44210



Dear Mr. Raineri

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Report (EPA 5002) (MOR) was received for your public water system for the month of March 2007.

Ohio Administrative Code (OAC) Rule 3745-83-01 requires that plant production or gallons per day produced by the water treatment plant be recorded daily and reported on EPA5002 with the required operational tests for the facility. If your plant does not have a water meter, a water meter shall be installed in consultation with Ralph Baker, District Engineer (419-373-3048).

If you have any questions regarding this letter, please contact me at (419) 373-3101.

Sincerely,

Ben Smith  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/lb

pc: Mike Gunder, Fostoria Mobile Estates  
Connie McCormick, Fostoria Mobile Estates  
Seneca County Health Department

DDAGW, NWDO:File

ec: Ralph Baker, DDAGW, NWDO