



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Seneca County
Village of Green Springs
Community Water System
PWS ID #: 7400512

October 1, 2008

OH7400512

GREEN SPRINGS VILLAGE PWS

10/1/2008

James Smith, BPA President
Village of Green Springs
P.O. BOX 362
Green Springs, OH 44836



Dear Mr. Smith:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Reports (EPA 5002) (MOR) were received for your public water system for August 2008.

Chlorine residual must be maintained throughout the entire distribution system at a minimum of 0.2 mg/L free chlorine or 1.0 mg/L combined chlorine in accordance with OAC Rule 3745-83-01(C)(1). The minimum chlorine residual in the distribution system was not maintained for 6 days in August 2008.

The Village of Green Springs is in violation of OAC Rule 3745-83-01(C)(1) for not maintaining the minimum chlorine residual throughout the entire distribution system.

If you have any questions as a result of this letter, please contact me at (419) 373-3101.

Sincerely,

Ben Smith
Division of Drinking and Ground Waters
Northwest District Office

/csl

cc: Seneca County Health Department
Toni Buchanan, IMS, DDAGW, CO
Lonnie McGhee, Operator
DDAGW.NWDO File