




Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

OH7401412

HOPEWELL ESTATES MHP

5/27/2011



Re: Seneca County  
Hopewell Estates MHP  
Community Water System  
PWS ID# OH7401412

May 27, 2011

Mr. Robert Lyn Makeever  
Hopewell Estates MHP  
8702 State Route 18; Lot #4  
Fostoria, Ohio 44830

Dear Mr. Makeever:


The December 2010, Drinking Water Operation Report (EPA 5002) received for your public water system does not meet the requirements as set forth in Ohio Administrative Code (OAC) Rule 3745-83-01.

OAC Rule 3745-83-01 requires that each community and major non-community water system maintain a minimum of 0.2 mg/l free chlorine residual or 1.0 mg/l combined chlorine residual measured at representative points throughout the distribution system.

Free and combined chlorine residuals are required to be conducted at the plant tap and in the distribution system daily (seven days per week) according to OAC Rule 3745-83-01. Your operational report shows this is not being done. Please correct this violation on your next monthly operating report.

If you have any questions regarding this letter, please contact me at (419) 373-3105.

Yours truly,

  
Curtis A. Eldridge  
Division of Drinking and Ground Waters

/cs

pc: Seneca County Health Department  
DDAGW, NWDO File :