


John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



Re: Seneca County
Hopewell Estates MHP
Community Public Water System
PWS ID# OH7401412

March 7, 2011

Mr. Robert Lyn Makeever
Hopewell Estates LLC-LE
P. O. Box 1155
Bucyrus, Ohio 44820

Notice of Violation – Monthly Report

Dear Mr. Makeever:


The Plant – Distribution Monthly Operation Report (EPA Form 5002) failed to report daily free and combined residuals in the distribution system.

OAC Rule 3745-83-01 (G) (1)(2) requires all community public water systems to monitor for free and combined chlorine residual **at least once every day that water is available to the public** at the entry point to the distribution system and a representative point in the distribution system.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3107 or via e-mail to Elizabeth.ames@epa.state.oh.us.

Sincerely,



Elizabeth Ames
Division of Drinking and Ground Waters

/llr

pc: Janet Makeever
Seneca County Health Department
DDAGW-NWDO.File