



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-9461 FAX: (419) 352-8468
www.epa.ohio.gov

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Seneca County
Hopewell Estates MHP
Community Water System
PWS ID# 7401412

June 8, 2010

OH7401412

HOPEWELL ESTATES MHP

6/8/2010

Mr. Robert Lyn Makeever
Owner
Hopewell Estates MHP
8702 State Route 18; Lot #4
Fostoria, Ohio 44830



Dear Mr. Makeever:

The February 2010, March 2010, and April 2010, Drinking Water Operation Reports (EPA 5002) received for your public water system do not meet the requirements as set forth in OAC Rule 3745-83-01.

Ohio Administrative Code, Rule 3745-83-01 requires that each community and major non-community water system maintain a minimum of 0.2 mg/l free chlorine residual or 1.0 mg/l combined chlorine residual measured at representative points throughout the distribution system.

Free and combined chlorine residuals are required to be conducted at the plant tap and in the distribution system daily (seven days per week) according to OAC Rule 3745-83-01. Your operational report shows this is not being done. Please correct this violation on your next monthly operating report.

If you have any questions regarding this letter, please contact me at (419) 373-3105.

Yours truly,

Curtis A. Eldridge
Division of Drinking and Ground Waters

/cs

pc: Seneca County Health Department
cDDAGW;NWDO:File