



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director

Re: Seneca County  
Poplar Village MHP  
Community Water System  
PWS ID. NO: 7401212

September 29, 2008

OH7401212

POPLAR VILLAGE MHP

9/29/2008

Mr. Don Garner, Owner  
Poplar Village MHP  
2930 Geer Road, Suite 105  
Turlock, California 95382-1142



**Re: 2007 Consumer Confidence Report**

Dear Mr. Garner:

The Ohio Environmental Protection Agency (Ohio EPA) received the 2007 Consumer Confidence Report (CCR) for the Pelton Mobile Home Park on July 14, 2008. The CCR was reviewed for the required content. Based on our review, the Pelton Mobile Home Park water system is in violation of the Ohio Administrative Code (OAC) Rules 3745-96-01 through 04 for failure to comply with the CCR requirements. The following minor violations were noted:

1. The Table of Detected Contaminants contained inaccurate information. The following contaminants were detected in 2007 and should have been reported in the CCR:

Treatment Plant 1 = The Arsenic running annual average (RAA), Barium, Fluoride, and Nickel

Treatment Plant 2 = The Arsenic RAA, Barium, Fluoride, Nickel, and Selenium

2. Total Chlorine residual levels must be reported in the table with the highest running annual average and a range of low to high monthly detections. (These levels can be found on the Total Chlorine Residual Quarterly Operating Reports form 5114.)

Be sure to correct the violation(s) as appropriate in your next CCR. The next report for calendar year 2008 must be sent to your customers by no later than July 1, 2009. A copy of the CCR along with a Certification Form must be submitted to the Ohio EPA, Northwest District Office at the above address. Violations in future reports may result in further enforcement action.

Mr. Don Garner, Owner  
September 29, 2008  
Page 2

The CCR template and template guide are accessible on our website:  
[www.epa.state.oh.us/ddagw](http://www.epa.state.oh.us/ddagw).

If you have any questions, please contact me at 419-373-3101.

Sincerely,

*Ben Smith*

Ben Smith  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/llr

pc: Seneca County Health Department  
<DDAGW, NWDO:File >