



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Seneca County
Pelton Trailer Park
Community Water System
PWS ID# 7401212

OH7401212

POPLAR VILLAGE MHP

4/26/2007

April 26, 2007

Mr. Richard Pelton
Pelton Trailer Park
1309 N. Twp. Rd. 21
Fostoria, Ohio 44830



Dear Mr. Pelton:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Report (EPA 5002) (MOR) was received for your public water system for the month of March 2007.

Ohio Administrative Code (OAC) Rule 3745-83-01 requires that plant production or gallons per day produced by the water treatment plant be recorded daily and reported on EPA5002 with the required operational tests for the facility. If your plant does not have a water meter, a water meter shall be installed in consultation with Ralph Baker, District Engineer (419-373-3048).

Contact Linda Benham at the Ohio EPA, Northwest District Office in regard to a low interest loan to purchase the meters or to tie the Park into the City of Fostoria water supply at 419-373-4117.

If you have any questions, please contact me at 419-373-3101.

Sincerely,

Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

/lb

pc: Seneca County Health Department
~~DDAGW; NWDO File~~