



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director

August 13, 2008

Re: Van Wert County  
Middle Point Water Treatment Plant  
Community Water System  
PWS ID#OH8100312

Maurice D Lewis  
Village Administrator  
Village of Middle Point  
103 N Adams Street  
P.O. Box 191  
Middle Point, OH 45963-0191

OH8100312 MIDDLE POINT WATER TREATMENT PLANT 8/13/2008



Subject: 2007 CCR

Ohio EPA received the 2007 Consumer Confidence Report (CCR) for the Middle Point Water Treatment Plant Public Water System on July 8, 2008. The CCR was reviewed for the required content. Based on our review, the Middle Point Water Treatment Plant Public Water System is in violation of the Ohio Administrative Code (OAC) Rules 3745-96-01 through 04 for failure to comply with the CCR requirements. The following deficiencies were noted:

1. Failure to include a definition for Maximum Residual Disinfectant Level (MRDL).
2. The Table of Detected Contaminants contained contaminants that were not detected: Total Coliform, Nitrate, and Toluene.
3. The Table of Detected Contaminants shall include the MRDLG for Total Chlorine.
4. Failure by July 1, 2008 to provide to the director a copy of the report and a distribution certification on a form acceptable to the director.

Be sure to correct the violations as appropriate in your next CCR. The next Consumer Confidence Report for calendar year 2008 must be sent to your customers by no later than July 1, 2009. A copy of the CCR along with a Certification Form must be submitted to the Northwest District Office at the above address. The CCR template and template guide are accessible on our website: [www.epa.state.oh.us/ddagw](http://www.epa.state.oh.us/ddagw).

If you have any questions, please contact me at 419-373-3042.

Sincerely,

Larry W. Moritz  
Division of Drinking and Ground Waters

/cs/

pc: Van Wert County Health Department  
◀DDAGW/NWDO.