




**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

OH8601512

AQUA OHIO - SENECA

11/23/2010



Re: Williams County
Aqua Ohio - Seneca
Community Water System
PWS ID# OH8601512
STU ID# 8659820

November 23, 2010

Mr. Louis Kreider
Aqua Ohio, Inc. – Seneca
8644 Station Street
Mentor, Ohio 44060

RE: Notice of Violation – Monthly Report

Dear Mr. Kreider:

The September 2010 Plant – Distribution Monthly Operation Report (EPA Form 5002) was received by the Ohio EPA-Northwest District Office on October 5, 2010.

Plan approval dated March 24, 1967, states equipment has been installed to remove iron from the drinking water. Iron is to be maintained at less than 0.3 milligrams per liter (mg/l). The September 2010 monthly reports show this is not being done. Take steps to reduce the finished water iron levels to below 0.3 mg/l.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3089 or via e-mail to jill.schiefer@epa.state.oh.us.

Sincerely,

Jill A. Schiefer
Division of Drinking and Ground Waters

/cs

pc: Williams County Health Department
~~DDAGW, NWDO File~~

ec: Bill Newsome, Operator