



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

Re: Williams County
Northland Community MHP
Community Water System
PWS ID #: 8601112

OH8601112

NORTHLAND SENIOR COMMUNITY

9/30/2008

September 30, 2008

Tim Smith
Northland Community MHP
103 A Degroff Ave
PO Box 218
Archbold, Oh 43502



Re: 2007 Consumer Confidence Report

Dear Mr. Smith:

The Ohio Environmental Protection Agency (Ohio EPA) received the 2007 Consumer Confidence Report (CCR) for Northland Community MHP on June 5, 2008. The CCR was reviewed for the required content. Based on our review, the Northland Community MHP water system is in violation of the Ohio Administrative Code (OAC) Rules 3745-96-01 through 04 for failure to comply with the CCR requirements. The following minor violations were noted:

1. The Table of Detected Contaminants contained incorrect information.

The Total Chlorine level and range of detections are inaccurately reported. The highest quarterly running annual average should be reported for the level found and the range of the highest and lowest monthly levels should be reported for the range of detections. The correct level found should have been reported as 0.22 mg/L and the range of detections should be reported as 0.1 mg/L to 0.8 mg/L.

The 2007 detection of Radium 228 should have been reported in the table of detected contaminants.

The chromium detection reported was non-detect and therefore should not be reported in the table of detected contaminants.


Be sure to correct the violation(s) as appropriate in your next CCR. The next report for calendar year 2008 must be sent to your customers by no later than July 1, 2009. A copy of the CCR along with a Certification Form must be submitted to the Ohio EPA, Northwest District Office at the above address. Violations in future reports may result in further enforcement action.

Mr. Tim Smith
September 30, 2008
Page Two

The CCR template and template guide are accessible on our website at www.epa.state.oh.us/ddagw .

If you have any questions, please contact me at 419-373-3101.

Sincerely,



Ben Smith
Division of Drinking and Ground Waters
Northwest District Office

/lb

cc: Dawn Smith, Office Manager
Williams County Health Department
~~DDAGW-NWBO-File~~