



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Williams County
Northland Park MHP
Community Water System
PWS ID # 8601112
STU ID # 8659817

April 30, 2007

OH8601112

NORTHLAND SENIOR COMMUNITY

4/30/2007

Mrs. Dawn Smith
Northland Community LLC
103 DeGross Avenue, Suite A
P.O. Box 218
Archbold, Ohio 43502



Dear Mrs. Smith:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Report (EPA 5002) (MOR) was not received for Northland Park MHP for the month of February 2008.

Free and combined chlorine residuals are required to be conducted at the plant tap and in the distribution system daily (seven days per week) according to OAC Rule 3745-83-01(G). Ohio Administrative Code (OAC), Rule 3745-83-01(I), requires submittal of an operational report no later than the tenth of the month following the month being reported [e.g., The March monthly operational report should be submitted to the district office no later than April 10th].

The owner / operator of Northland Community MHP is in violation of OAC Rule 3745-83-01(G), OAC Rule 3745-83-01(I) for not completing the above requirements.

If you have any questions regarding this letter, please contact me at (419) 373-3101.

Sincerely,

Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

/l/r

pc: Albert Charles, Park Manager
Williams County Health Department
BDAGW, NWDO File