



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Williams County
Northland Mobile Home Park
Community Water System
PWS ID # 8601112


February 23, 2007

OH8601112

NORTHLAND SENIOR COMMUNITY

2/23/2007

Mr. Tim Smith, Manager
Midwest Property Management
103 Degroff Avenue, Suite A
Archbold, Ohio 43502



Dear Mr. Smith:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Report (EPA 5002) (MOR) was not received for your public water system for the month of January 2007.

Free and combined chlorine residuals are required to be conducted at the plant tap and in the distribution system daily (seven days per week) for all community public water systems according to OAC Rule 3745-83-01(G). In addition, plant production or gallons per day produced by the water treatment plant shall be recorded daily and reported on EPA5002 in accordance with OAC Rule 3745-83-01. If your plant does not have a water meter, a water meter shall be installed in consultation with Debbie Ko, District Engineer (419-373-3106).

Ohio Administrative Code (OAC) Rule 3745-83-01(I), requires submittal of a monthly operational report, on form EPA 5002, no later than the tenth of the month following the month being reported [e.g., February's monthly operational report should be submitted to the district office no later than March 10th]. Copies of the EPA 5002, Plant - Distribution Monthly Operation Report form are attached.

If you have any questions regarding this letter, please contact me at (419) 373-3101.

Sincerely,

Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

/llr

Attachment

pc: Williams County Health Department
DDAGW, NWDO File