




**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

OH8601212

OAKWOOD MHP

11/23/2010



Re: Williams County
Oakwood MHP
Community Water System
PWS ID# OH8601212
STU ID#1 8659818
STU ID#2 8660632

November 23, 2010

Mr. Steve Faliski, Chief Operating Officer
Jamison Management Company
1025 East Maple Road, Suite B-1
Birmingham, Michigan 48009

Notice of Deficiency – Monthly Report

Dear Mr. Faliski:

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported hardness less than one hundred milligrams per liter (mg/l) in October 2010.

The softened finished water is to be maintained between 100 – 150 mg/l of hardness as calcium carbonate. The October 2010 monthly report shows this is not being done.

Take steps to correct this deficiency.

Failure to take action to address this deficiency may result in a violation in the future.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3089 or via e-mail to jill.schiefer@epa.state.oh.us.

Sincerely,

Jill A. Schiefer
Division of Drinking and Ground Waters

/cs

pc: Williams County Health Department
(DDAGW, NWDO File)
Eric Kurfis, Certified Operator