


Northv

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 3
ww



—
or
or
or

Re: Williams County
Williams Co. Hillside Country Living
Community Water System
PWS ID. #: 8601912

January 4, 2007

Mr. Paul Heisey, Environmental Services Director
Williams County Hillside Country Living
09876 County Road 16
Bryan, Ohio 43506

Dear Mr. Heisey:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Report (EPA 5002) (MOR) was received for your public water system for the month of November 2006.

However, all community public water systems must maintain a minimum chlorine residual of at least two-tenths milligram per liter (0.2 mg/l) free chlorine, or one milligram per liter (1.0 mg/l) combined chlorine at representative points in the distribution system according to Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1). Review of the MOR documents that the required levels were not maintained for eight days in November.

The facility is in violation of OAC Rule 3745-83-01(C)(1) for not maintaining adequate daily chlorine residual in the distribution.

If you have any questions regarding this letter, please contact me at (419) 373-3101.

Sincerely,

Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

/csl

pc: Williams County Health Department
Toni Buchanan, IMS, DDAGW, CO
DDAGW, NWDO File