



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

OH8700612

CYGNET VILLAGE WATER

11/23/2010



Re: Wood County
Village of Cygnet
Community Water System
PWS ID# OH8700612
STU ID# 8759906

November 23, 2010

Mr. Lon Shank, President
Board of Public Affairs
Village of Cygnet
210 Front Street
P. O. Box 408
Cygnet, Ohio 43413

RE: Notice of Violation – Monthly Report

Dear Mr. Shank:

The October 2010 Plant – Distribution Monthly Operation Report (EPA Form 5002) was received by the Ohio EPA-Northwest District Office on November 10, 2010.

Plan approval from the director of the Ohio EPA, dated February 22, 2002, states the finished softened water will be maintained between 100 – 150 mg/l of hardness as calcium carbonate. The October 2010 monthly reports show this is not being done. Be sure the weekly hardness samples are being properly taken (i.e., not during backwash of the units).

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3089 or via e-mail to jill.schiefer@epa.state.oh.us.

Sincerely,

Jill A. Schiefer
Division of Drinking and Ground Waters

/cs

pc: Wood County Health Department
~~DDAGW;NWDO;File~~