



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.ohio.gov

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Wood County  
Village of Cygnet  
Community Water System  
PWS ID# OH8700612  
STU ID# 8759906

May 19, 2010

Mr. Lon Shank, President  
Board of Public Affairs  
210 Front Street  
P. O. Box 408  
Cygnet, Ohio 43413

OH8700612

CYGNET VILLAGE WATER

5/19/2010



RE: Notice of Violation – Monthly Report

Dear Mr. Shank:

The April 2010 Plant – Distribution Monthly Operation Report (EPA Form 5002) was received late by the Ohio EPA-Northwest District Office on May 13, 2010.

Ohio Administrative Code Rule 3745-83-01(1)(2) requires the operation report to be submitted to the district office no later than the tenth of the month following the month for which the report was prepared (i.e. May's monthly operational report should be submitted to the district office no later than June 10<sup>th</sup>). The operational report is to be signed by the operator in responsible charge designated in accordance with rule 3745-7-02 of the Administrative Code.

Plan approval dated February 22, 2002, approved by the director of the Ohio EPA states the finished softened water will be maintained at about 100 mg/l of hardness as calcium carbonate. The March and April 2010 monthly reports show this is not being done. Readjust the softeners and the bypass water to be able to maintain this level of hardness. Install a meter that can be read standing on the floor, not from the top of a ladder for the safety of the plant operator. Be sure the weekly hardness samples are being properly taken (i.e., not during backwash of the units).

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3089 or via e-mail to [jill.schiefer@epa.state.oh.us](mailto:jill.schiefer@epa.state.oh.us).

Sincerely,

Jill A. Schiefer  
Division of Drinking and Ground Waters

/cs

pc: Wood County Health Department  
DDAGW;NWDO File

ec: Linda Benham, DDAGW-NWDO

