



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

OH8704312

FIVE POINT MHP

3/17/2011



Re: Wood County  
Five Point Mobile Home Park  
Community Water System  
PWS ID# OH8704312  
STU ID # 8759928

March 17, 2011

Ms. Michelle Myers, Owner  
Five Point Mobile Home Park  
24370 McCutchenville Road  
Perrysburg, Ohio 43551

**RE: Notice of Violation – Monthly Report**

Dear Ms. Myers:

The February 2011 Plant – Distribution Monthly Operation Report (EPA Form 5002) was received by the Ohio EPA-Northwest District Office on March 10, 2011.

OAC Rule 3745-83-01(C)(1) requires a system which adds chlorine to maintain a minimum of 0.2 mg/l free chlorine residual or 1.0 mg/l combined chlorine residual measured at representative points throughout the distribution system. A review of the February 2011 MOR shows 7 days during the month a chlorine residual was not being maintained in the distribution system. Take steps to immediately correct this problem.

OAC Rule 3745-83-01(I)(1) requires a system to report free chlorine residual and combined chlorine residual daily on the monthly operational report from the **plant tap** and in **distribution**.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3089 or via e-mail to [jill.schiefer@epa.state.oh.us](mailto:jill.schiefer@epa.state.oh.us).

Sincerely,

Jill A. Schiefer  
Division of Drinking and Ground Waters

/cs

pc: Wood County Health Department  
DDAGW-NWDO File