



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Wood County
Five Point MHP
Community Water System
PWS ID# 8704312

February 27, 2007

OH8704312

FIVE POINT MHP

2/27/2007

Ms. Michelle Myers, Owner
Five Point MHP
24370 McCutchenville Road; Lot #33
Perrysburg, Ohio 43551



Subject: Notice of Violation for Operational Reports at Five Point MHP

Dear Ms. Myers:

The January 2007 Drinking Water Operation Report (EPA 5002) was received for Five Point Mobile Home Park on February 22, 2007.

Ohio Administrative Code (OAC) Rule 3745-83-01(I)(2) requires submittal of an operation report no later than the tenth of the month following the month being reported. (i.e., October's monthly report should be submitted to the district office no later than November 10th.)

OAC Rule 3745-83-01(G) requires a community public water system to monitoring for **free and combined chlorine residual at least once every day** that water is available to the public at the entry point (plant tap) and in distribution. This information is to be recorded daily on Form EPA 5002.

The December 2006 and the January 2007 MOR Form EPA5002 only show combined chlorine residual results daily. Correct this on your next monthly report and show free and combined chlorine residual at the plant tap and in distribution daily.

OAC Rule 3745-81-27 requires that a DPD colorimeter test kit with electronic measurement of the color development be used to test daily for free chlorine and combined chlorine. The DPD colorimeter test kit shall be able to detect to a limit of 0.1 mg/l. **It is acceptable to test for free chlorine and total chlorine daily, but free chlorine and combined chlorine must be reported on Form EPA 5002. This can be done by: free chlorine – total chlorine = combined chlorine.**


Ms. Michelle Myers
February 27, 2007
Page Two

The Total Chlorine Residual Quarterly Operating Report shows an average of 30.6 mg/l total chlorine residual for the month of December 2006. This data reported does not accurately document the level of chlorine in your water system. The accurateness of the monthly and quarterly reports is a requirement of the Ohio EPA. Failure to correct this matter may result in further violations or enforcement actions.

OAC Rule 3745-83-01(I)(2) requires that the operation report be signed by the operator in responsible charge of the water system as designated in OAC Rule 3745-7-02. Our records show Michelle Myers as the operator in responsible charge. Michelle Myers' operator certification number is not being reported on the monthly reports. Correct this on the next monthly report.

If you have any questions regarding this letter, please contact me at (419)373-3089 or via email at jill.schiefer@epa.state.oh.us.

Sincerely,



Jill A. Schiefer
Environmental Specialist II
Division of Drinking and Ground Waters

/cs

pc: Wood County Health Department
Toni Buchanan, IMS, DDAGW, CO
~~DDAGW, NWDO File~~

ec: Lisa Jones-Gast, Supervisor, DDAGW, NWDO
Ellen Gerber, Manager, DDAGW, NWDO