




Environmental
Protection Agency

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

OH8703903

NORTHWESTERN W AND SD-BAIRDSTOWN

11/23/2010



* 0 H 8 7 0 3 9 0 3 1 1 2 3 2 0 1 0 N O V *

Re: Wood County
NWWSD-Bairdstown
Community Water System
PWS ID# 8703903

November 23, 2010

Mr. Jerry Greiner, Executive Director
Northwestern Water & Sewer District
12560 Middleton Pike
P. O. Box 348
Bowling Green, Ohio 43402

Notice of Violation – Monthly Report

Dear Mr. Greiner:

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l in the distribution system on 17 days in October 2010.

OAC Rule 3745-83-01(C)(1) requires all community public water systems to maintain a minimum chlorine residual of at least two-tenths mg/l free chlorine or one mg/l combined chlorine measured at representative points throughout the distribution system.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3089 or via e-mail to jill.schiefer@epa.state.oh.us.

Sincerely,

Jill A. Schiefer
Division of Drinking and Ground Waters

/cs

pc: Wood County Health Department
~~DDAGW;NWDO-File~~