



**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korleski, Director

OH8703903

NORTHWESTERN W AND SD-BAIRDSTOWN

11/23/2010



Re: Wood County  
NWWSD-Bairdstown  
Community Water System  
PWS ID# 8703903

November 23, 2010

Mr. Jerry Greiner, Executive Director  
Northwestern Water & Sewer District  
12560 Middleton Pike  
P. O. Box 348  
Bowling Green, Ohio 43402

### Notice of Violation – Monthly Report

Dear Mr. Greiner:

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l in the distribution system on 9 days in September 2010.

OAC Rule 3745-83-01(C)(1) requires all community public water systems to maintain a minimum chlorine residual of at least two-tenths mg/l free chlorine or one mg/l combined chlorine measured at representative points throughout the distribution system.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3089 or via e-mail to [jill.schiefer@epa.state.oh.us](mailto:jill.schiefer@epa.state.oh.us).

Sincerely,

Jill A. Schiefer  
Division of Drinking and Ground Waters

/cs

pc: Wood County Health Department  
DDAGW;NWDO;File