



Environmental  
Protection Agency

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korfeski, Director

OH8703903

NORTHWESTERN W AND SD-BAIRDSTOWN

9/14/2010



Re: Wood County  
NWWSD-Bairdstown  
Community Water System  
PWS ID# 8703903

September 14, 2010

Mr. Jerry Greiner, Executive Director  
Northwestern Water & Sewer District  
12560 Middleton Pike  
P. O. Box 348  
Bowling Green, Ohio 43402

**Re: Notice of Violation – Monthly Report**

The July 2010 Drinking Water Operation Report (EPA 5002) for Northwestern Water and Sewer District-Bairdstown was received on August 05, 2010.

OAC Rule 3745-83-01(C)(1) requires a system which adds chlorine to maintain a minimum of 0.2 mg/l free chlorine residual or 1.0 mg/l combined chlorine residual measured at representative points throughout the distribution system. A review of the July 2010 report shows 14 days during the month a chlorine residual was not being maintained in the distribution system. Take steps to immediately correct this problem.

OAC Rule 3745-83-01(I)(1) requires a system to report free chlorine residual and combined chlorine residual daily on the monthly operational report from the plant tap and in distribution.

If you have any questions regarding this letter or any other matter involving your water system, please feel free to contact me at (419)373-3089 or via email at [jill.schiefer@epa.state.oh.us](mailto:jill.schiefer@epa.state.oh.us).

Sincerely,

Jill A. Schiefer  
Environmental Specialist  
Division of Drinking and Ground Waters

/cs

pc: Wood County Health Department  
DDAGW, NWDO File