



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

OH8704203

NORTHWESTERN W AND SD-WTLN 200

8/18/2011



Re: Wood County
NWWSD-WTLN 200
Community Water System
PWS ID# 8704203

August 18, 2011

Mr. Jerry Greiner, Executive Director
Northwestern Water & Sewer District
12560 Middleton Pike
P. O. Box 348
Bowling Green, Ohio 43402

RE: Notice of Violation – Monthly Report

The June 2011 Drinking Water Operation Report (EPA 5002) for Northwestern Water and Sewer District-WTLN 200 was received on July 7, 2011.

OAC Rule 3745-83-01(C)(1) requires a system which adds chlorine to maintain a minimum of 0.2 mg/l free chlorine residual or 1.0 mg/l combined chlorine residual measured at representative points throughout the distribution system. A review of June 2011, reveals 20 days during the month a chlorine residual was not being maintained in the distribution system. Take steps to immediately correct this problem.

If you have any questions regarding this letter or any other matter involving your water system, please feel free to contact me at (419) 373-3089 or via email at jill.schiefer@epa.state.oh.us.

Sincerely,

Jill A. Schiefer
Environmental Specialist
Division of Drinking and Ground Waters

/cs

pc: Wood County Health Department
DDAGW, NWDO File