



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

OH8704203

NORTHWESTERN W AND SD-WTLN 200

3/15/2011



Re: Wood County  
NWWSD-Waterline 200  
Community Water System  
PWS ID# OH8704203

March 15, 2011

Mr. Jerry Greiner, Executive Director  
Northwestern Water & Sewer District  
12560 Middleton Pike  
P. O. Box 348  
Bowling Green, Ohio 43402

**RE: Notice of Violation – Monthly Report**

The January 2011 Drinking Water Operation Report (EPA 5002) for Northwestern Water and Sewer District-Waterline 200 was received on February 9, 2011.

OAC Rule 3745-83-01(C)(1) requires a system which adds chlorine to maintain a minimum of 0.2 mg/l free chlorine residual or 1.0 mg/l combined chlorine residual measured at representative points throughout the distribution system. A review of January 2011 shows 4 days during the month a chlorine residual was not being maintained in the distribution system. Take steps to immediately correct this problem.

OAC Rule 3745-83-01(I)(1) requires a system to report free chlorine residual and combined chlorine residual daily on the monthly operational report from the plant tap and in distribution.

If you have any questions regarding this letter or any other matter involving your water system, please feel free to contact me at (419) 373-3089 or via email at [jill.schiefer@epa.state.oh.us](mailto:jill.schiefer@epa.state.oh.us).

Sincerely,

Jill A. Schiefer  
Environmental Specialist  
Division of Drinking and Ground Waters

/cs

pc: Wood County Health Department  
DAGW, NWDO File