



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korteski, Director

OH8704203

NORTHWESTERN W AND SD-WTLN 200

9/27/2010



Re: Wood County
NWWSD – Waterline #200
Community Public Water System
PWS ID# OH8704203

September 27, 2010

Mr. Jerry Greiner, Executive Director
Northwestern Water & Sewer District
12560 Middleton Pike
P. O. Box 348
Bowling Green, Ohio 43402

RE: Notice of Violation – Monthly Report

The August 2010 Drinking Water Operation Report (EPA 5002) for Northwestern Water and Sewer District – Waterline #200 was received on September 10, 2010.

OAC Rule 3745-83-01(C)(1) requires a system which adds chlorine to maintain a minimum of 0.2 mg/l free chlorine residual or 1.0 mg/l combined chlorine residual measured at representative points throughout the distribution system. A review of the August 2010 report shows nine days during the month a chlorine residual was not being maintained in the distribution system. Take steps to immediately correct this problem.

OAC Rule 3745-83-01(I)(1) requires a system to report free chlorine residual and combined chlorine residual daily on the monthly operational report from the plant tap and in distribution.

If you have any questions regarding this letter or any other matter involving your water system, please feel free to contact me at (419) 373-3089 or via email at jill.schiefer@epa.state.oh.us.

Sincerely,

Jill A. Schiefer
Environmental Specialist
Division of Drinking and Ground Waters

/cs

pc: Wood County Health Department
DBAGW;NWDO:File