



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korteski, Director

OH8703812

OTTERBEIN-PORTAGE VLY RETIRE CENTER

11/23/2010



Re: Wood County
Otterbein Portage Valley Retirement Community
Community Water System
PWS ID# OH8703812
STU ID# 8759923

November 23, 2010

Mr. Tom Keith, Executive Director
Otterbein Portage Valley Retirement Community
20311 Pemberville Road
Pemberville, Ohio 43450

RE: Notice of Violation – Monthly Report

Dear Mr. Keith:

The October 2010 Plant – Distribution Monthly Operation Report (EPA Form 5002) was received by the Ohio EPA-Northwest District Office on November 5, 2010.

Plan approval from the director of the Ohio EPA, dated May 14, 1979, shows two (2) ion-exchange softeners were installed to remove hardness from the drinking water. The finished softened water is to be maintained at a range of 100 – 150 mg/l of hardness as calcium carbonate. The October 2010 monthly reports show this is not being done.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3089 or via e-mail to jill.schiefer@epa.state.oh.us.

Sincerely,

Jill A. Schiefer
Division of Drinking and Ground Waters

/cs

pc: Wood County Health Department
DDAGW-NWDO:File
Ted Ross, Director of Maintenance
Mike Coyle, Director of Environmental Services

ec: Linda Benham, DDAGW-NWDO