



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Wood County
Village of Pemberville
Community Water System
PWS ID# OH8701712


January 4, 2008

OH8701712

PEMBERVILLE VILLAGE WATER

1/4/2008

Mr. Charles Aring, President
Board of Public Affairs
Village of Pemberville
115 Main Street
P. O. Box 109
Pemberville, Ohio 43450



Subject: Monthly Operation Report

Dear Mr. Aring:

The November 2007 Operation Report, EPA Form 5002, for the Village of Pemberville is incomplete.

Ohio Administrative Code, Rule 3745-83-01 requires that each community and major non-community water system maintain a minimum of 0.2 mg/l free chlorine residual or 1.0 mg/l combined chlorine residual measured at representative points daily throughout the distribution system.

Review of your November 2007 operation report indicated that free and combined chlorine residuals were not analyzed daily during the month.

Free and combined chlorine residuals are to be conducted at the plant and in the distribution system daily (7 days per week).

Arrangements need to be made for the free and combined chlorine residuals to be conducted at the plant and in the distribution system daily (7 days per week) when the superintendent of water is not available to perform these tests.

The free and combined chlorine residuals do not have to be performed by the certified operator. Someone else in the village can be taught to perform and record these tests when the certified operator is unavailable to perform them.

Mr. Charles Aring
January 4, 2008
Page Two

If you have any questions, feel free to contact me at (419)373-3089 or via email at jill.schiefer@epa.state.oh.us.

Sincerely,



Jill A. Schiefer
Environmental Specialist II
Division of Drinking and Ground Waters

/cs

pc: Superintendent of Water
Wood County Health Department
Toni Buchanan, IMS, DDAGW, CO
~~DDAGW, NWDO, File~~