



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

OH8701912

PERRYSBURG ESTATES MHP

11/23/2010



Re: Wood County
Perrysburg Estates MHP
Community Water System
PWS ID# OH8701912
STU ID# 8759915

November 23, 2010

Mr. Kamal Chehayeb, President
Choice Properties, Inc.
755 West Big Beaver, Suite 1275
Troy, Michigan 48084

Notice of Violation – Monthly Report

Dear Mr. Chehayeb:

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported hardness less than one hundred milligrams per liter (mg/l) in October 2010.

Plan approval from the director of the Ohio EPA shows ion-exchange softeners were installed to remove hardness. The softened finished water is to be maintained between 100 – 150 mg/l of hardness as calcium carbonate. The October 2010 monthly reports show this is not being done. Take steps to correct this problem.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3089 or via e-mail to jill.schiefer@epa.state.oh.us.

Sincerely,

Jill A. Schiefer
Division of Drinking and Ground Waters

/cs

pc: Wood County Health Department
~~DDAGW; NWDO File~~