



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Wood County
Village Green MHP
Community Water System
PWS ID# 8702412

April 22, 2008

OH8702412

VILLAGE GREEN MHP

4/22/2008

Mr. David Nightingale, Owner
Village Green MHP
7630 Reitz Road – Office
Perrysburg, Ohio 43551



Re: Monthly Reports Violation

Dear Mr. Nightingale:

The March 2008 Drinking Water Operating Report (EPA 5002) for Village Green MHP was received on April 10, 2008.

Review of the monthly operational report for your water system indicates that the daily water usage is not being recorded. Ohio Administrative Code, Rule 3745-83-01(I)(1)(c) requires a water system to record plant production or gallons per day produced by the water treatment plant. Village Green MHP was informed of this in writing in a letter dated October 31, 2007.

The above operational requirements are to be corrected in your next monthly operating report.

Yours truly,

Jill A. Schiefer
Environmental Specialist II
Division of Drinking and Ground Waters

/cs

pc: Chad Johnson, Operator of Record
Wood County Health Department
DDAGW, NWDO File