



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.ohio.gov

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Wood County
Village of Wayne
Community Water System
PWS ID# OH8703112
STU ID# 8759920

May 26, 2010

OH8703112

WAYNE VILLAGE WATER

5/26/2010

Mr. Joe St. Clair, Village Administrator
Village of Wayne
125 Schoolhouse Street
P. O. Box 39
Wayne, Ohio 43466



RE: Notice of Violation – Monthly Report

Dear Mr. St. Clair:

The April 2010 Plant – Distribution Monthly Operation Report (EPA Form 5002) was received late by the Ohio EPA-Northwest District Office on May 11, 2010.

Ohio Administrative Code Rule 3745-83-01(1)(2) requires the operation report to be submitted to the district office no later than the tenth of the month following the month for which the report was prepared (i.e. May's monthly operational report should be submitted to the district office no later than June 10th). The operational report is to be signed by the operator in responsible charge designated in accordance with rule 3745-7-02 of the Administrative Code.

Failure to take action to address this violation may result in enforcement action being taken.

The hardness level was low several times in April 2010. Hardness is to be kept in the range of 80 – 150 mg/l. Readjust the amount of water being bypassed to keep the hardness in this range.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3089 or via e-mail to jill.schiefer@epa.state.oh.us.

Sincerely,

Jill A. Schiefer
Division of Drinking and Ground Waters

/cs

pc: Wood County Health Department
DDAGW-NWDO-File

