



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.ohio.gov

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korfeski, Director

Re: Wood County
Village of Wayne
Community Water System
PWS ID# OH8703112
STU ID# 8759920

February 11, 2010

Certified Mail 7009 1680 0002 4297 1080

OH8703112

WAYNE VILLAGE WATER

2/11/2010

Mr. Joe St. Clair, Village Administrator
Village of Wayne
125 Schoolhouse Street
P. O. Box 39
Wayne, Ohio 43466



Subject: Notice of Violation for Failure to Respond to a Significant Deficiency

This letter is notification that the Village of Wayne has not complied with requirements issued during this Agency's last survey performed on November 30, 2009, in violation of rule 3745-81-60 of the Ohio Administrative Code. The village was notified in correspondence dated December 23, 2009, to respond in writing no later than 45 days, with time frames for:

- 1. OAC Rule 3745-9-04 (A)(6) states, "Potential sources of contamination shall not be constructed or placed within the sanitary isolation radius of a public water system well."

The required isolation radius for Well #3 is 300 feet. However, a potential source of contamination (storm sewer line) is located within the isolation radius. The village is working on finding a funding source to move this line. The village can apply for an Ohio EPA revolving loan to help fund this project. A preapplication is due to Ohio EPA by March 15, 2010. You may call us for assistance with this application.

- 2. OAC Rule 3745-95-06(C)(3) states "The consumer shall, on any premises on which backflow prevention devices required... are installed, have thorough inspections and operational tests made of the devices at the time of installation or repair, and as may be reasonably required by the supplier of water or the director, but in all cases at least once every twelve months." In addition, OAC Rule 3745-95-06 (C)(2) states "It shall be the duty of the supplier of water to see that the tests and inspections...are made."

Have all the backflow devices located in the water plant inspected at least every twelve months, at the time of installation or repair of the device.

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.

661

Mr. Joe St. Clair
February 11, 2010
Page Two

If you have any questions, please contact me at (419) 373-3089 or via email at jill.schiefer@epa.state.oh.us.

Sincerely,

Jill A. Schiefer
Environmental Specialist
Division of Drinking and Ground Waters

/cs

pc: Dave Bornino, CO - DDAGW/OFAS
Wood County Health Department
DDAGW, NWDO File

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:
Mr. Joe St. Clair
Village of Wayne
125 Schaalhouse
PO Box 39
Wayne, Ohio 43466

2. Arti (Tra) 7009 1680 0002 4297 1080

COMPLETE THIS SECTION ON DELIVERY

A. Signature
Miss Melissa Repas

B. Received by (Printed Name)
Miss Melissa Repas

C. Date of Delivery
2.22.10

D. Is delivery address different from item 1? Yes
If YES, enter delivery address below: No

3. Service Type
 Certified Mail
 Registered
 Insured Mail
 Express Mail
 Return Receipt for Merchandise
 C.O.D.

4. Restricted Delivery? (Extra Fee) Yes

PS Form 3811, February 2004
Domestic Return Receipt
102595-02-M-1540
dpaw/jill/cs