



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Wood County
Wayne Village Water
Community Water System
PWS ID# 8703112

October 29, 2007

OH8703112

WAYNE VILLAGE WATER

10/29/2007

Mr. Joe St. Clair, Village Administrator
Village of Wayne
125 Schoolhouse Street
P. O. Box 39
Wayne, Ohio 43466



Dear Mr. St. Clair:

The April 2007, May 2007, and June 2007 Drinking Water Operation Reports (EPA 5002) for the Village of Wayne were received late on July 27, 2007.

Ohio Administrative Code (OAC) Rule 3745-83-01 requires submittal of an operational report no later than the tenth of the month following the month being reported (i.e. May's monthly operational report should be submitted to the district office no later than June 10th).

The second quarter 2007 total chlorine residual quarterly operating report (EPA 5114) for the Village of Wayne was also received late on July 27, 2007.

Disinfection residual measurements are required to be taken for **total chlorine** according to OAC Rule 3745-81-70 (E) at the same time total coliform bacterial samples are collected. The total chlorine residuals obtained during routine and repeat total coliform bacterial monitoring events are to be reported on the QOR by the 10th of the month following the end of the calendar quarter being reported. [i.e., The second calendar quarter (April - June) should be submitted to the district office no later than July 10th.]

If you have any questions regarding this letter or any other matter involving your water system, please feel free to contact me at (419) 373-3089 or via email at jill.schiefer@epa.state.oh.us.

Sincerely,

Jill A. Schiefer
Environmental Specialist II
Division of Drinking and Ground Waters

/cs

pc: Wood County Health Department
DDAGW-NWDO-File