



State of Ohio E

OH0254212

ALLEN EAST LOCAL SCHOOLS

1/22/2008

North



\* 0 H 0 2 5 4 2 1 2 1 2 2 2 0 0 8 N O V \*

ior  
ior

Chris Korleski, Director

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (41

Re: Allen County  
Allen East Local School  
Non-Transient Non-Community System  
PWS ID# 0254212

January 22, 2008

Mr. Miké Richards  
Allen East Local Schools  
9105 Harrod Road  
Harrod, Ohio 45850

Dear Mr. Richards:

The Ohio EPA, Division of Drinking and Ground Waters (DDAGW), Water Plant – Distribution Monthly Operating Reports (EPA 5002) (MOR) were received for the months of October, November and December 2007 for Allen East Local School.

Free and combined chlorine residuals are required to be conducted at the **plant tap and in the distribution system daily** (all days people are at the school and have access to the water) in accordance with Ohio Administrative Code (OAC) Rule 3745-83-01(G).

A chlorine residual must be maintained throughout the entire distribution system at a minimum of 0.2 mg/L free chlorine or 1.0 mg/L combined chlorine in accordance with OAC Rule 3745-83-01(C)(1).

**Allen East Local Schools is in violation of OAC Rule 3745-83-01(G) for not conducting and/or reporting daily chlorine residuals at the plat tap and in the distribution system for the month of October 2007.**

**Allen East Local School is in violation of OAC Rule 3745-83-01(C)(1) for not maintaining the minimum chlorine residual throughout the distribution system for the months of October and November 2007.**

If you have any questions as a result of this letter, please contact me at (419) 373-3101.

Sincerely,

Ben Smith  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/lb

pc: Toni Buchanan, IMS, DDAGW, CO  
Mick Dearth, Allen East Local Schools  
Wes Hites, Operator of Record  
Allen County Health Department  
~~DDAGW, NWDO, File, Allen East Local School~~