



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Allen County
Landeck Elementary School
Non-Transient Non-Community System
PWS ID# 0253512

March 27, 2007

OH0253512

LANDECK ELEMENTARY SCHOOL

3/27/2007

Mr. Mark Fuerst, Principal
Landeck Elementary School
14750 Landeck Rd.
Landeck, Ohio 45833



Dear Mr. Fuerst:

The January and February 2007 Bromate Monthly Operating Report (EPA 5116) for Landeck Elementary School has not been received.

OAC Rule 3745-81-23(L) states that, "All community and nontransient noncommunity public water systems that treat their water with ozone shall monitor to determine compliance with the maximum contaminant level for bromate in rule 3745-81-11 of the Administrative Code.

Ohio Administrative Code (OAC), Rule 3745-83-01(F), requires submittal of an operational report no later than the tenth of the month following the month being reported. (i.e., January's monthly operating report must be submitted to the district office no later than February 10th.)

The monthly bromate samples completed for the facility must be reported monthly by the tenth of the following month on the EPA 5116 form. A copy of the EPA 5116 form and instructions for completion are attached.

If you have any questions, please contact me at (419) 373-3101.

Sincerely,

Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Water

/csl

with attachment

pc: Mike Leis, Operator (with attachment)
Allen County Health Department
DDAGW, NWDO File