



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Allen County
Procter & Gamble
NT Non-Community System
PWS ID: 0254312


November 1, 2007

OH0254312

PROCTER & GAMBLE DIST CTR - LIMA

11/1/2007

Todd Hoffman
Procter & Gamble
3875 Reservoir Rd.
Lima, Ohio 45801



Dear Mr. Hoffman:

The Ohio EPA, Division of Drinking and Ground Waters (DDAGW), Water Plant – Distribution Monthly Operating Reports (EPA 5002) (MOR) were received for the months of August and September 2007 for Procter and Gamble.

Free and combined chlorine residuals are required to be conducted at the **plant tap and in the distribution system daily** (seven days a week) in accordance with OAC Rule 3745-83-01(G).

Procter and Gamble is in violation of OAC Rule 3745-83-01(G) for not conducting and/or reporting daily chlorine residuals at the plat tap and in the distribution system.

Hardness, Iron, and Manganese monitoring must be completed in accordance with OAC Rule 3745-83-01(G)(8), (9), and (10). Ann Scott confirmed in a telephone conversation on November 1, 2007 that these test are being performed weekly. Ensure that the above tests are performed weekly and recorded on the MOR to avoid future violations of OAC Rule 3745-83-01(G).

If you have any questions, please contact me at 419-373-3101.

Sincerely,

Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

/lb

pc: Allen County Health Department
Ann Scott, IFM
Norman Phillibert, Procter & Gamble
Brad Longberry, Flag City Water
~~DDAGW, NWDO File~~