Ohio | Environmental Protection Agency

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

OH3239812 RIVERDALE LOCAL SCHOOLS 12/16/2010

OH3239812121620 10NOV

Re: Hancock County
Riverdale Local School District
NTNC Water System
PWS ID# OH3239812
STU ID# 3261712

December 16, 2010

Corrected Letter

Mr. Eric Hoffman, Superintendent
Riverdale Local Schools
20613 State Route 37
Mt. Blanchard, Ohio 45867

RE: Notice of Deficiency – Monthly Report

Dear Mr. Hoffman:

The September 2010 Plant – Distribution Monthly Operation Report (EPA Form 5002) was received by the Ohio EPA-Northwest District office on October 5, 2010.

Plan approval dated November 3, 2003, by the director of the Ohio EPA states the finished softened water will be maintained between 100 – 150 mg/l of hardness as calcium carbonate. The September 2010 monthly reports show this is not being done. Take steps to correct this problem.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3089 or via e-mail to jill.schiefer@epa.state.oh.us.

Sincerely,

for

Jill A. Schiefer
Division of Drinking and Ground Waters

/cs

pc: Hancock County Health Department
~~DDAGW-NWDO File~~

ec: Bill Newsome, Operator

Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402-9398

419 | 352 8461
419 | 352 8468 (fax)
www.epa.ohio.gov