



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

Re: Hancock County
Riverdale Local School District
NTNC Water System
PWS ID# OH3239812
STU ID# 3261712

November 23, 2010

OH3239812

RIVERDALE LOCAL SCHOOLS

11/23/2010

Mr. Eric Hoffman, Superintendent
Riverdale Local Schools
20613 State Route 37
Mt. Blanchard, Ohio 45867



RE: Notice of Violation – Monthly Report

Dear Mr. Hoffman:

The September 2010 Plant – Distribution Monthly Operation Report (EPA Form 5002) was received by the Ohio EPA-Northwest District Office on October 5, 2010.

Plan approval by the director of the Ohio EPA dated November 3, 2003, states the finished softened water will be maintained between 100 – 150 mg/l of hardness as calcium carbonate. The September 2010 monthly reports show this is not being done. Take steps to correct this problem.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3089 or via e-mail to jill.schiefer@epa.state.oh.us.

Sincerely,

Jill A. Schiefer
Division of Drinking and Ground Waters

/cs

pc: Putnam County Health Department
DDAGW;NWDO File

ec: Bill Newsome, Operator