



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director

Re: Hancock County  
Riverdale Local Schools  
NTNC Water System  
PWS ID# 3239812  
STU ID# 3261718

March 2, 2007

Dr. Joyce Plummer, Superintendent  
Riverdale Local Schools  
20613 State Route 37  
Mt. Blanchard, Ohio 45867

OH3239812

RIVERDALE LOCAL SCHOOLS

3/2/2007



Dear Dr. Plummer:

The January 2007 Drinking Water Operation Report form EPA 5002 for the Riverdale Local Schools was received February 12, 2007.

Ohio Administrative Code (OAC) Rule 3745-83-01 was revised in October 2006. OAC Rule 3745-83-01 (G) requires a public water system that provides water treated with chlorine to monitor for free chlorine and combined chlorine at least once every day that the water is available to the public at each entry point to the distribution system (plant tap) and a representative point in the distribution system.

Therefore, the Riverdale Local Schools is required to monitor for free chlorine and combined chlorine on days the school building is being used by students, staff and guests. This may include weekend usage (i.e., basketball games on Saturday night or a club meeting on Sunday afternoon). Review the building usage and start monitoring and recording this information when needed.

The results of the daily free and combined chlorine residuals are to be recorded and reported on the monthly operational report which is due to the district office no later than the tenth of the month following the month for which the report was prepared. The operation report is to be signed by the operator in responsible charge of the water system.

If you have any questions concerning this matter, please feel free to contact me at (419)373-3089 or via email at jill.schiefer@epa.state.oh.us.

Yours truly,

Jill A. Schiefer  
Environmental Specialist II  
Division of Drinking and Ground Waters

/cs  
pc: Hancock County Health Department  
Toni Buchanan, IMS, DDAGW, CO  
DDAGW, NWDO File

ec: Ellen Gerber, Manager, DDAGW, NWDO  
Lisa Jones-Gast, Supervisor, DDAGW, NWDO  
William Newsome, Operator