



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Hancock County  
Trinity Lutheran School  
NTNC Water System  
PWS ID# 3245912

October 5, 2007

OH3245912

TRINITY EVANGELICAL LUTHERAN SCHOOL

10/5/2007

Alois Schmitzer, III; Pastor  
Trinity Evangelical Lutheran Church  
301 North Main Street  
P. O. Box 2  
Jenera, Ohio 45841



**Subject: Notice of Violation for Failure to Respond to a Significant Deficiency**

Dear Pastor Schmitzer:

This letter is notification that the Trinity Lutheran School has not complied with requirements issued during this Agency's last survey performed on June 26, 2007, and is in violation of rule 3745-81-60 of the Ohio Administrative Code (OAC). The school was notified in correspondence dated July 10, 2007, to respond in writing no later than 45 days, with time frames for:

- OAC Rule 3745-9-05(O)(2) requires a finished grade to be sloped so as to direct surface water away from the well. Maintain an appropriate finished grade around the well casing, as needed.

The water system must respond in writing within 15 days from the date of this letter with the required information concerning the well having the appropriate finished grade around the casing. Failure to comply may result in further enforcement action. This written notification can be satisfied by submitting a picture of the well casing with the appropriate finished grade by U.S. mail or via email.

If you have any questions, please contact me via email at [jill.schiefer@epa.state.oh.us](mailto:jill.schiefer@epa.state.oh.us) or call me at (419)373-3089.

Sincerely,

Jill A. Schiefer  
Environmental Specialist II  
Division of Drinking and Ground Waters

/cs

pc: Hancock County Health Department  
Dave Evans, DDAGW, CO

~~DDAGW, NWDO File~~  
ec: JoAnn Sabo, DDAGW, NWDO