



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Hardin County
Ohio Fresh Eggs, LLC- Mt Victory
NTNC Public Water System
PWS ID: OH3335112
STU ID: 3354929

OH3335112

OHIO FRESH EGGS, LLC-MT VICTORY

4/20/2009

April 20, 2009

Mr. David Fabian
Northern Compliance Officer
20449 County Road 245
Mt. Victory, Ohio 43340



Dear Mr. Fabian:

Review of the Drinking Water Plant-Distribution Monthly Operation Report, for the reporting period of March 2009 noted, the plant had difficulty in meeting the treatment objective for free and combined chlorine residuals. The free chlorine residual was reported at less than 0.2 mg/l on ten days. Please investigate and take any corrective measures that are necessary. Notify this office of any actions taken.

Questions may be directed to my attention at (419) 373-3042.

Sincerely,

Larry W. Moritz, R.S., M.S.I.H.
Division of Drinking and Ground Waters

/lb

pc: Hardin County Health Department
~~DDAGW/NWDO~~