



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korfeski, Director

Re: Hardin County
Ohio Fresh Eggs, LLC-Mt Victory
NTNC Public Water System
PWS ID: OH3335112
STU ID: 3354929

October 15, 2008

OH3335112

OHIO FRESH EGGS, LLC-MT VICTORY

10/15/2008

Mr. David Fabian
Northern Compliance Officer
20449 County Road 245
Mt. Victory, Ohio 43340



Dear Mr. Fabian:

Review of the Drinking Water Plant-Distribution Monthly Operation Report for the reporting period of September 2008, noted the plant is failing to meet the distribution residual goal at the entry point of 0.5 to 1.0 mg/l. In addition, the free chlorine residual within the distribution system was less than 0.2 mg/l on fifteen days. Please investigate and submit a report with the Plant-Distribution Monthly Operation Report for the reporting period of November 2008, with a summary of your findings and any corrective measures that are taken. To assist in your investigation, I have enclosed an AWWA Ohio Section Technology Committee "White Paper on Disinfection with Hypochlorites" for your review.

Questions may be directed to my attention at 419-373-3042.

Sincerely,

Larry W. Moritz
Division of Drinking and Ground Waters

/llr

pc: Myron Lawler, Managing Consultant
Hardin County Health Department

DDAGW-NWDO File

ec: Ralph Baker, District Engineer, DDAGW/NWDO
Linda Benham, Supervisor, DDAGW/NWDO