



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Hardin County  
Ohio Fresh Eggs, LLC - Mt Victory  
NTNC Water System  
PWS ID# OH3335112


November 21, 2007

OH3335112

OHIO FRESH EGGS, LLC-MT VICTORY

11/21/2007

Mr. Harry Palmer  
Director of Operations  
Ohio Fresh Eggs, LLC  
11212 Croton Road  
Croton, Ohio 43013



**Subject: Plant-Distribution Monthly Operation Report (MOR) for October 2007**

Dear Mr. Palmer:

Review of the Plant-Distribution Monthly Operation Report (MOR) for October 2007; noted the following:

- failure to report chlorine residuals for October 27 & 28.
- 22 days either the plant, distribution, or both reported a chlorine residual below a free chlorine residual of 0.2 mg/l or a combined chlorine residual of 1.0 mg/l.
- the values ranged from 2.2 mg/l to 0.01 mg/l.

Within 14 days, provide a written response regarding the desired treatment goal and steps taken to achieve it.

Finally, a Limited Scope Site Visit is scheduled for 10:00 a.m. on December 11, 2007.

If you have questions, please contact me at 419-373-3042.

Sincerely,

Larry Moritz  
Division of Drinking and Ground Waters

/llr

cc: ~~DDAGW-NWDO~~ File

ec: Linda Benham, Supervisor, DDAGW-NWDO