



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Hardin County  
Scioto Sign Company, Inc  
NTNC Public Water System  
PWS ID#OH3333112

November 17, 2008

Mr. Shawn Moore, President  
Scioto Sign Company, Inc  
6047 U.S. Route 68 North  
Kenton, Ohio 43326

OH3333112

SCIOTO SIGN CO INC

11/17/2008



Dear Mr. Moore:

Plant Distribution Monthly Operation Reports (MOR) (Form EPA 5002) for the reporting periods of August 2008, September 2008, and October 2008, were received on November 10, 2008. Review of the reports found each to be incomplete in that they:

1. Failed to report at least monthly the level of hardness. Ohio Administrative Code (OAC) rule 3745-83-01 (G)(8)(a) states: "A public water system serving fewer than two hundred and fifty persons that provide ion exchange treatment or membrane technology to reduce hardness shall monitor for hardness at least monthly at each entry point to the distribution system using a state certified laboratory."
2. The reports were not signed by the operator in responsible charge designated in accordance with OAC rule 3745-7-02 as required by OAC rule 3745-83-01 (I)(2).

Take appropriate action to submit the MOR for November 2008 in full compliance with OAC rule 3745-83-01. Questions may be directed to my attention at 419-373-3042.

Sincerely,

Larry W. Moritz  
Division of Drinking and Ground Waters

/llr

pc: DDAGW/NWDO  
Hardin County Health Department