




John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



Re: Henry County  
Campbell Soup Supply Company  
NT Non-Community Water System  
PWS ID# OH3531411

November 1, 2011

Mr. Geoffrey Sans  
Campbell Soup Supply Company  
12-773 State Route 110  
Napoleon, Ohio 43545

**Subject: Notice of Violation - Failure to meet the treatment technique turbidity requirements in rules 3745-81-71 through 3745-81-75 of the Ohio Administrative Code (OAC) April 2011 – Single Exceedance**

The Campbell Soup Supply Company water system failed to provide sufficient filtration of its drinking water when the turbidity levels of representative samples of its filtered water exceeded one nephelometric turbidity unit (NTU) on April 3, 2011.

Failure to meet any requirement of OAC rule 3745-81-73, Filtration of Water from Surface Water Sources, is a treatment technique violation for which public notice is required under OAC rule 3745-81-32. OAC Rule 3745-81-75 (E) states "If at any time the turbidity in representative samples of filtered water...exceeds one NTU, for conventional or direct filtration or alternative filtration surface water systems, the public water system shall notify the director as soon as practical, but no later than twenty-four hours after the exceedance is known." Campbell Soup Supply Company is required to provide a public notice as soon as practical, but no later than 24 hours after the system learns of the violation or situation, using one or more of the forms of delivery identified in the table below (Refer to Step 1).

Actions required as a result of the above violation	
Step 1	<p><b>Use one or more of the following methods to reach all persons served by the public water system:</b></p> <ol style="list-style-type: none"> <li>1. Public notice issued by appropriate broadcast media (such as radio and television)</li> <li>2. Public notice issued by continuous posting in conspicuous places throughout the area served by the water system</li> <li>3. Public notice issued by hand delivery to persons served by the water system</li> <li>4. Public notice issued by another delivery method approved in writing</li> </ol>
Step 2	Initiate an investigation and take the necessary steps to correct the problem as soon as possible.

Mr. Geoffrey Sans  
November 2, 2011  
Page 2

Actions required as a result of the above violation	
Step 3	Within <b>10 days</b> of completing Step 1, fill out the attached verification form and send it along with a copy of the public notification issued to the Northwest District Office of Ohio EPA.

If you have any questions, please contact me at (419) 373-4118.

Sincerely,



Justin W. Bowerman  
Division of Drinking and Ground Waters

llr/

Enclosures

pc: Mike Maringer, Operator of Record (w/ enclosures)  
Henry County Health Department  
Julie Gillenwater, DDAGW, CO  
Toni Buchanan, DDAGW, CO  
DDAGW, NWDO, File (w/ enclosures)

# DRINKING WATER NOTICE

## Campbell Soup Supply Company Did Not Meet Treatment Requirements

We routinely monitor our water for turbidity (cloudiness). This tells us whether we are effectively filtering the water supply. A water sample taken April 3, 2011 showed turbidity levels of 2.99 turbidity units. This is above the standard of one turbidity unit. Because of these high levels of turbidity, there is an increased chance that the water may contain disease-causing organisms. We are required to consult with the director of Ohio EPA within twenty-four hours after learning of this violation. We did not contact Ohio EPA within 24 hours.

### What should I do?

- **You do not need to boil the water or take other actions.** The violation with health concerns occurred on April 3, 2011. We do not know of any contamination, and none of our testing has shown disease-causing organisms in the drinking water. However, if you have specific health concerns, contact your doctor.
- *Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease causing organisms. These organisms include bacteria, viruses, and parasites, which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches. People with severely compromised immune systems, infants, and some elderly people may be at increased risk. These people should seek advice about drinking water from their health care providers.*
- The symptoms above are not caused only by organisms in drinking water. If you experience any of these symptoms and they persist, you may want to seek medical advice.

### What is being done?

We are investigating and taking the necessary steps to correct the problem as soon as possible.

For more information, please contact \_\_\_\_\_ at \_\_\_\_\_ or \_\_\_\_\_  
name of contact phone number mailing address

General guidelines on ways to lessen the risk of infection by microbes are available from the EPA Safe Drinking Water Hotline at 1(800) 426-4791.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

PWSID#: OH3531411 Date distributed: \_\_\_\_\_

**PUBLIC NOTICE INSTRUCTIONS AND VERIFICATION FORM FOR TIER 1 VIOLATIONS**

The owner or operator of a public water system with a Tier 1 violation or situation that may pose an acute risk to human health is required to notify the persons served by the public water system. Notice shall be issued as soon as practical but **no later than 24 hours** after the system learns of the violation. Public notice shall be repeated as established during consultation with Ohio EPA.

I HEREBY CERTIFY THAT THE PUBLIC WAS NOTIFIED BY THE FOLLOWING METHOD(S) INDICATED BELOW, AS DESCRIBED IN THE OHIO ADMINISTRATIVE CODE RULE 3745-81-32:

Required Method of Public Notification	Actual Method of Public Notification
<p>Use one or more of the following methods to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> <li>1. Public notice issued by appropriate broadcast media (such as radio and television stations)</li> <li>2. Public notice issued by continuous posting in conspicuous places throughout the area served by the water system</li> <li>3. Public notice issued by hand delivery to persons served by the water system</li> <li>4. Public notice issued by another delivery method approved in writing</li> </ol>	<p>Describe actual methods used to notify public of the violation:</p> <p>1A. Name of station(s) _____</p> <p>1B. Date provided to station(s) _____</p> <p>2A. Dates of posting _____</p> <p>2B. Locations of posting _____</p> <p>3. Date of delivery _____</p> <p>4A. Method _____</p> <p>4B. Date _____</p>
<p><b>Additional methods established in consultation with Ohio EPA</b></p>	<p>A. Method(s) _____</p> <p>B. Date(s) _____</p>

Please check if the public notice used was provided by Ohio EPA (other side of this form) or another acceptable notice was used:

A public notice as shown on the other side of this sheet was issued without changes.

A different public notice was issued. **INCLUDE A COPY OF THE PUBLIC NOTICE.**

\_\_\_\_\_  
Signature of Responsible Person                      Date

\_\_\_\_\_  
Printed Name and Title of Responsible Person

PWS Name: Campbell Soup Supply Co.  
PWS ID: OH3531411  
County: Henry County  
Monitoring Period: April 2011  
Violation Type: 43

<b>For Ohio EPA use only</b>	
Date PN received: _____	_____
PN acceptable: _____	PN not acceptable: _____