



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.ohio.gov

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director


Re: Henry County
Campbell Soup Supply Company
NT Non-Community Water System
PWS ID# OH3531411

February 3, 2010

OH3531411 CAMPBELL SOUP SUPPLY CO

43 02/03/10

Mr. Geoffrey Sans
Campbell Soup Supply Company
12-773 State Route 110
Napoleon, Ohio 43545



Subject: Notice of Violation - Failure to meet the treatment technique turbidity requirements in rules 3745-81-71 through 3745-81-75 of the Ohio Administrative Code (OAC)

The Campbell Soup Supply Company water system failed to provide sufficient filtration of its drinking water when the turbidity levels of representative samples of its filtered water exceeded 1 nephelometric turbidity unit (NTU) on January 27, 2010.

Failure to meet any requirement of OAC Rule 3745-81-73, Filtration of Water from Surface Water Sources, is a treatment technique violation for which public notice is required under OAC Rule 3745-81-32.

Actions required as a result of the above violation	
Step 1	Within 30 days issue the attached public notice of the violation in accordance with Rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system: Posting the notice in conspicuous locations throughout the distribution system frequented by persons served by the system, or by mail or direct delivery to each customer and service connection (where known). If the public notice is posted, the notice shall remain in place for as long as the violation or situation persists, but in no case for less than seven days, even if the violation or situation is resolved; and If the above method does not reach all persons served , any other method reasonably calculated to reach other persons served by the system if they would not normally be reached. Other methods may include: publication in a local newspaper or newsletter distributed to customers; use of E-mail to notify employees. If the notice is posted, it shall remain in place as long as the violation exists, but in no case less than 7 days.
Step 2	Initiate an investigation and take the necessary steps to correct the problem as soon as possible.
Step 3	Within 10 days of completing Step 1, fill out the attached verification form and send it along with a copy of the public notification issued to the Northwest District Office of Ohio EPA.

Mr. Geoffrey Sans
February 3, 2010
Page Two

If you have any questions, please contact me at (419) 373-4118.

Sincerely,



Justin W. Bowerman
Division of Drinking and Ground Waters

/cs

Enclosures

pc: Mike Maringer, Operator of Record (w/ enclosures)
Henry County Health Department
Toni Buchanan, DDAGW, CO
~~DDAGW, NWDO, File (w/ enclosures)~~

DRINKING WATER NOTICE

Campbell Soup Supply Company Did Not Meet Treatment Requirements

We routinely monitor our water for turbidity (cloudiness). This tells us whether we are effectively filtering the water supply. A water sample taken January 27, 2010, showed turbidity levels of 5.1 turbidity units. This is above the standard of one turbidity unit. Because of these high levels of turbidity, there is an increased chance that the water may contain disease-causing organisms.

What should I do?

- **You do not need to boil the water or take other actions.** We do not know of any contamination, and none of our testing has shown disease-causing organisms in the drinking water.
- *Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease causing organisms. These organisms include bacteria, viruses, and parasites, which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches. People with severely compromised immune systems, infants, and some elderly people may be at increased risk. These people should seek advice about drinking water from their health care providers.*
- The symptoms above are not caused only by organisms in drinking water. If you experience any of these symptoms and they persist, you may want to seek medical advice.

What is being done?

We are investigating and taking the necessary steps to correct the problem as soon as possible.

For more information, please contact _____ at _____ or _____
name of contact phone number mailing address

General guidelines on ways to lessen the risk of infection by microbes are available from the EPA Safe Drinking Water Hotline at 1(800) 426-4791.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWSID#: OH3531411 Date distributed: _____

