



State of Ohio Environmental Protection Agency

OH3531411


CAMPBELL SOUP SUPPLY CO

2/28/2007

Northwest

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-
www



Re: Henry County
Campbell Soup Supply Company
NT Non-Community Water System
PWS ID #: 3531411

February 28, 2007

Mr. Kevin Rippee
Campbell Soup Supply Company
12-773 State Route 110
Napoleon, Ohio 43545

SUBJECT: Notice of Maximum Contaminant Level Violation -- Exceedance of Contaminant Level (MCL) for chlorite established by rule 3745-81-11 of the Ohio Administrative Code (OAC).

This letter is notification that your public water system is in violation of OAC rule 3745-81-11 for exceeding the chlorite MCL.

Violation: Exceedance of the Chlorite MCL
Period of Violation: January 21, 2007
Chlorite MCL: 1.0 mg/L Chlorite results: 1.126 mg/L

User Notification Required. You must notify your water users of this monitoring violation in accordance with OAC rule 3745-81-32. Refer to the enclosures for instructions, an example public notice, and a verification form.

Sincerely,

Justin W. Bowerman
Environmental Specialist II
Division of Drinking and Ground Waters

/lb

Enclosures

cc: Henry County Health Dept.
Aaron McCoy, Operator (w/ enclosure)
Mike Maringer, Technical Supervisor (w/ enclosure)
Toni Buchanan, DDAGW-CO
DDAGW\NWDO.File
version 6-11-02

DRINKING WATER NOTICE

Campbell Soup Supply Company Has Levels of Chlorite Above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for Chlorite. The average level of chlorite for January 2007 was 1.126 mg/L. The standard for Chlorite is 1.0 mg/L.

What should I do?

- **You do not need to use an alternative (e.g., bottled) water supply.** However, if you have specific health concerns, consult your doctor.

What does this mean?

The levels detected do not pose an immediate risk to your health. However, some infants and young children who drink water containing chlorite in excess of the MCL could experience nervous system effects. Similar effects may occur in fetuses of pregnant women who drink water containing chlorite in excess of the MCL. Some people may experience anemia.

What is being done?

We are investigating and taking the necessary steps to correct the problem as soon as possible.

For more information, please contact _____ at _____ or _____ .
name of contact phone number mailing address

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWSID#: _____ STUID#: _____ Date distributed: _____