



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Mercer County
S & K Products Company
NTNC Water System
PWS ID #5440312

September 18, 2007

OH5440312 S AND K PRODUCTS COMPANY

22 09/18/07

Mr. V. J. Westerheide, President
S & K Products Company
4540 U.S. Route 127
P.O. Box 166
Coldwater, OH 45828



**Subject: Notice of Violation -
Monthly Maximum Contaminant Level for Total Coliform Bacteria**

Your public water system incurred a **monthly** violation of Ohio Administrative Code (OAC), Rule 3745-81-14 in September, 2007 due to the following results:

Sample Date	Sample Tap	Total Coliform	E. Coli	Fecal Coliform	Sample Number	Lab Cert Number
9-11-07	Bay #2 RR - 1	Positive	Negative	-	91107058	840
9-11-07	Bay #2 RR - 2	Positive	Negative	-	91107057	840
9-11-07	Bay #2 RR - 3	Positive	Negative	-	91107056	840
9-11-07	Bay #2 RR - 4	Positive	Negative	-	91107055	840


A monthly violation of OAC, Rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

Actions required as a result of the above violation	
Step 1	Within 30 days issue the attached public notice of the violation in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served by the public water system: posting in conspicuous locations (restrooms, drinking fountains, vending areas, bulletin boards, etc.).
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	You are required to monitor with at least five (5) samples in the next month following any total coliform-positive result. You must take at least five (5) total coliform samples in October, 2007 .

Mr. V.J. Westerheide
September 18, 2007
Page 2

If you have any questions, please contact me at (419) 373-3088.

Sincerely,



John A. (Jack) Schwartz
Division of Drinking and Ground Waters

JW/csl

Enclosures

pc: Andrew J. Will, Operations Manager
Toni Buchanan, DDAGW, CO
Mercer County Health Department
~~(DDAGW-NWDO File)~~