



State of Ohio Environ

OH6332212

LAFARGE NORTH AMERICA - PAULDING

4/30/2008

**Northwest**

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8  
www.ohio.gov



\* 0 H 6 3 3 2 2 1 2 4 3 0 2 0 0 8 N O V \*

OHIO INDIAN, DIRECTOR

Re: Paulding County  
Lafarge North America  
NTNC Water System  
PWS ID# 6332212

April 30, 2008

Mr. Timothy Weible, Sr. Environmental Manager  
Lafarge North America  
11435 County Road 176  
P.O. Box 160  
Paulding, Ohio 45879

Dear Mr. Weible:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Report (EPA 5002) (MOR) was not received for the public water system for the month of March 2008.

Free and combined chlorine residuals are required to be conducted at the plant tap and in the distribution system daily (seven days per week) in accordance with Ohio Administrative Code (OAC) Rule 3745-83-01(G). OAC Rule 3745-83-01(I), requires submittal of an operational report no later than the tenth of the month following the month being reported [e.g., The March monthly operational report should be submitted to the district office no later than April 10<sup>th</sup>].

**The owner / operator of Lafarge North America is in violation of OAC Rule 3745-83-01(G) and OAC Rule 3745-83-01(I) for not completing the above requirements.**

In addition, the Ohio EPA, Total Chlorine Residual Quarterly Operating Report (EPA 5114) (QOR) has not been received for the calendar quarter of January to March 2008.

Disinfection residual measurements are required to be taken for **total** chlorine according to Ohio Administrative Code (OAC) Rules 3745-81-70 (E) at the same time total coliform bacterial samples are collected. The total chlorine residuals obtained during routine and repeat total coliform bacterial monitoring events are to be reported on the QOR by the 10<sup>th</sup> of the month following the end of the calendar quarter being reported. [e.g., the first calendar quarter (January - March) should be submitted to the district office no later than April 10<sup>th</sup>.]

**The owner/operator of Lafarge North America is in violation of OAC Rule 3745-81-70(E) for not meeting the aforementioned requirement.**

Mr. Timothy Weible, Sr. Environmental Manager  
April 30, 2008  
Page 2

If you have any questions regarding this letter, please contact me at (419) 373-3101.

Sincerely,



Ben Smith  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/llr

pc: Ottawa County Health Department  
Toni Buchanan, IMS, DDAGW, CO  
~~DDAGW, NWDO File~~