




Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

OH6945612

THE SCHNIPKE ENGRAVING COMPANY INC

9/30/2011



Re: Putnam County
NTNC PWS
Schnipke Engraving
PWS ID# OH6945612
STU ID# 6957644

September 30, 2011

Ms. Eileen Halter
14223 Road 24
Ottoville, Ohio 45876

Violation of the secondary standard for iron - NOV OAC 3745-82-02

Dear Ms. Halter:

Notice of Violation

The Plant – Distribution Monthly Operation Report (EPA Form 5002) reported Iron greater than three-tenths milligrams per liter (mg/l) on August 5, 2011.

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for iron which is 0.3 mg/l. There was one (1) week during the month in which iron exceeded the secondary standard.

Monitoring and compliance determinations for the secondary maximum contaminant level for iron are as follows:

- (a) Public water systems shall use the monitoring required by OAC 3745-83-01 (F)(5) to determine compliance with the secondary maximum contaminant level for iron.
- (b) A public water system shall be in violation of the secondary standard for iron when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

Violation of the secondary standard for iron does not require public notification. Please review your operations to determine the reason for the exceedance and advise this office as to what corrections will be made.

Ms. Eileen Halter
September 30, 2011
Page 2

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3101 or via e-mail to Chris.Riddle@epa.state.oh.us.

Sincerely,



Chris Riddle
Environmental Specialist 2
Division of Drinking and Ground Waters

/lr

pc: Putnam County Health Department
David Erhart, Operator
DDAGW-NWDO File